



H/C-11

Memo No:- 363

Date:- 19.04.2021

Subject : Physical / Chemical Examination Report of Water Sample

Sample Details		Date & Time
Sample ID:	HSR/03553/4/2021	
Sample Classification:	Private	
Sender:	BABA BANDA BAHADUR PUBLIC SCHOOL, HANSI 3800	15/04/2021 at 09:58
Location :-	Near Old Tehsil Office, Hansi	15/04/2021 at 12:17
		19/04/2021
Latitude :-	75.955226	Longitude :- 29.091313

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Limit (In the Absence of Alternate Source)
1	Total Dissolved Solids	100.6	500 mg/lit.	2000 mg/lit.
2	Total Hardness as CaCO ₃	30	200 mg/lit.	600 mg/lit.
3	Flouride as F	0.32	1.0 mg/lit.	1.5 mg/lit.
4	pH	6.54	6.5 - 8.5	6.5 - 8.5
5	Turbidity	2	1 NTU	5 NTU

Remarks :-

- * The Results Given above are related to the sample as received and tested in HISAR Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.

Water Sample has been found "CONFORMING" to Limits set in BIS10500:2012 for the tested parameters.
Based on the tested parameters, the water sample is found "Potable"



Rohy
RAJEEV KUMAR, CHEMIST
DISTRICT WATER TESTING LABORATORY, HISAR
email:-chemist.hisar@phedharyana.gov.in

-----End of Report-----

[Signature]
Principal
Baba Banda Bahadur
Public School, Hansi
Aff. No. : 530532
School No. : 20147

[Signature]
President
Baba Banda Bahadur
Public School, HANSI

19/04/2021